

MATERIAL LIST

<u>ITEM</u>	<u>DESCRIPTION</u>	<u>ITEM</u>	<u>DESCRIPTION</u>
①	LONG BODY SLEEVE	⑩	2" THREADED BRASS NIPPLES (3" LONG)
②	DI SPOOL (FLxPE), 3'-0" LONG	⑪	2" BALL VALVE WITH PADLOCK WINGS AND THREADED ENDS
③	DI TEE (FLxFLxFL) WITH BLIND FLANGE WITH 2" IPT TAP	⑫	2" BRASS ST ELL
④	RESILIENT SEAT GATE VALVE (FLxFL) WITH HAND WHEEL	⑬	2" THREADED BRASS PIPE, LENGTH TO FIT
⑤	FCA	⑭	2" BRASS FLANGE METER COUPLINGS
⑥	6" DI SPOOL (FLxPE), 1'-7" LONG 4" DI SPOOL (FLxPE), 2'-2" LONG 3" DI SPOOL (FLxPE), 2'-8" LONG	⑮	2" METER, DISTRICT TO PROVIDE
⑦	NOT USED	⑯	ADJUSTABLE PIPE SUPPORT EQUAL TO STANDON #S92
⑧	METER (FLxFL), DISTRICT TO PROVIDE	⑰	FREE STANDING GALVANIZED STEEL LADDER, ATTACH TO FLOOR AND SIDE OF HATCH.
⑨	CONCRETE THRUST RESTRAINT WITH TIE RODS PER DISTRICT STANDARDS	⑱	4" FLOOR DRAIN W/ SCREEN 4" SCHEDULE 40 PVC PIPE

PAINTING SCHEDULE

CONCRETE EXTERIORS BELOW GRADE
SURFACE SHALL BE CLEAN AND DRY. PAINT WITH TWO COATS OF TNEMEC PRIMER SERIES 46-465 COAL TAR SOLUTION (OR EQUAL) 8.0 TO 10.0 MILS DFT.

CONCRETE INTERIORS
WALLS AND CEILINGS - TWO (2) COATS OF ICI DEVOE 4308-1000 WHITE
FLOORS - NONE.

METAL (EXCEPT FACTORY FINISH PAINTED EQUIPMENT)
ONE (1) SHOP COAT OF ICI DEVOE RUST BLOCK, 4100-7100 RED METAL PRIMER
TWO (2) COATS ICI DEVOE GROTTA BLUE D-104

3", 4" AND 6" COMPOUND METER SERVICE NOTES

WATER STANDARD DETAIL

NORTHEAST SAMMAMISH SEWER AND WATER DISTRICT

FILE	SCALE	DATE
SAMDTW27	NTS	10/01/97