## CONSTRAINTS


- SOIL CONDITIONS AND BEARING CHARACTERISTICS ARE TO BE DETERMINED BY THE DISTRICT.
- 2. THIS STANDARD DETAIL IS FOR HORIZONTAL THRUST RESTRAINT ONLY.
- 3. CONCRETE BLOCKING SHALL BE PER APWA SPECIFICATION 7-11.3(13) 1984.
- 4. CONCRETE THRUST BLOCKING FOR FITTINGS LARGER THAN 16" SHALL BE AS SHOWN ON THE PROJECT PLANS.
- 5. MAINTAIN 18" MINIMUM GROUND COVER OVER THE TOP OF ALL CONCRETE BLOCKING.

## **PROCEDURE**

- 1. DETERMINE BEARING FACTOR IN TABLE 1 CORRESPONDING TO APPROPRIATE PIPE SIZE AND TYPE OF FITTING.
- 2. MULTIPLY THE BEARING FACTOR DETERMINED IN TABLE 1 BY THE MULTIPLICATION FACTOR IN TABLE 2 FOR THE APPROPRIATE SOIL CLASSIFICATION.

THE RESULT IS THE REQUIRED AREA OF CONCRETE (IN SQ. FT.) WHICH MUST BEAR AGAINST UNDISTURBED SOIL.

- 3. USING TABLE 3 LOCATE THE MINIMUM DEPTH OF CONCRETE (Dmin) CORRESPONDING TO THE REQUIRED BEARING ÀREA.
- 4. USING Dmin, THE HEIGHT AND LENGTH OF THE THRUST BLOCKING CAN BE DETERMINED FROM THE DIMENSION RELATIONSHIPS ILLUSTRATED IN FIGURE 1 AND DESCRIBED BELOW:
  - A. "H" EQUALS "D"
  - B. MAX. "L" EQUALS 2 X "H"
    C. MIN. "L" EQUALS "H"







FIGURE 1

	TEST	TEES DEAD	90°	45°	22 1/2	11 1/4°
SIZE	PRESSUR	E ENDS	BEND	BEND	BEND	BEND
3	300	2.25	2.25	2.25	2.25	2.25
4	300	2.25	2.25	2.25	2.25	2.25
6	300	2.83	4.00	2.25	2.25	2.25
8	300	5.00	7.11	3.85	2.25	2.25
10	300	7.86	11.11	6.00	3.06	2.25
12	300	11.31	16.00	8.66	4.41	2.25
14	250	12.83	18.14	9.82	5.00	2.51
16	225	15.08	21.33	11.54	5.88	2.96
* 2.25 BASED ON GEOMETRIC FACTORS						

**BEARING FACTOR** 


TABLE 1





45° BEND






22 1/2° BEND

CROSS W/BLIND FLANGE





CAP

W/ SIZE OUTLET

SOIL CONDITION	MULTIPLICATION FACTOR
*MUCK, PEAT, etc.	_
SOFT CLAY	3.0
SAND	1.5
SAND AND GRAVEL	1.0
SAND AND GRAVEL CEMENTED W	/ CLAY 0.75
HARD SHALE	0.30

<sup>\*</sup> THRUST BLOCKING SHALL BE DESIGNED BY ENGINEER

MULTIPLICATION FACTOR **TABLE 2** 

REQ'D BEARING	MINIMUM DEPTH
AREA (SQ. FT.)	D <sub>MIN</sub>
2.25 MIN 5.0	1.5'
5.01 - 10.0	2.25'
10.01 - 15.0	3.0'
15.01 - 30.0	4.0'
30.01 - 40.0	4.5'
40.01 - 50.0	5.0'
50.01 - 70.0	6.0'

**BLOCK SHAPE** TABLE 3

## HORIZONTAL THRUST BLOCKING

## WATER STANDARD DETAIL

**NORTHEAST SAMMAMISH SEWER AND WATER DISTRICT** 

FILE	SCALE	DATE	
SAMDTW10	NTS	1/25/93	